



SCLA
QUALIFIED ELECTRICIAN SERVICES
PROJECT #CC16-088
April 27, 2016

ADDENDUM #1

The attached constitutes additional information and serves to clarify issues considered to be part of the Southern California Logistics Airport Authority "Qualified Electrician Services, Project CC16-088

RFI #1

1. Q: What type of electrical equipment and systems are involved?
A: Standard building and aircraft hangar electrical systems including hangar doors, high bay lightning and aircraft ground power systems.
2. Q: What type of electronic and digital components are involved?
A: Hangar doors, electrical panels and transformers.
3. Q: What type of Generators: brand, size?
A: Remove from scope.
4. Q: What is included in Air Handling Equipment?
A: Remove from scope.
5. Q: What type, sizes of electrical motors?
A: Various, not to exceed 480 volt, 3 phase.
6. Q: Various makes and manufacturers, some of which ceased production in the 1960's.
7. Q: What is meant by low-voltage communications systems?
A: Intercoms, telephones and the like.
8. Q: Form on Section D "List of Subcontractors" there is no way of calculating what the value of the total contract on as-needed basis contract.
A: Omit the percentage of total contract.

Please confirm receipt of this Addendum #1CC16-088, by either faxing the acknowledgment to the City of Victorville, Purchasing Division at (760) 269-0045, or by attaching the signed acknowledgment to your bid proposal. **Failure to acknowledge receipt of this addendum may result in the disqualification of your proposal.** The undersigned acknowledges receipt of ADDENDUM #1:

Name of Bidder_____

Address_____

Telephone No._____Fax No:_____

Signature:_____

Title Date